


Heat exchangers

water-oil




Water-oil heat exchangers, shell and tube type, permit to cool the heat in hydraulic plants.

They can operate on return line of the main hydraulic circuit, or on a separate circuit dedicated to cooling.

Heat exchangers are designed to work in hydraulic systems with mineral oil or synthetic fluids having similar lubricating characteristics.

Max oil flow up to 200 lt/min Pressure up to 12 bar




2 MAIN CHARACTERISTICS

Installation position	Horizontal suggested (clamping on feet)			
Hydraulic connections	Size, see section 2 and 8. Protect the heat exchanger setted at 4 - 5 bar	Protect the heat exchanger against pressure peaks on exhaust line with a by pass check valve		
Fluid	Hydraulic oil as per DIN 51	Hydraulic oil as per DIN 51524535; for other fluids contact our technical office		
Recommended viscosity	15 ÷ 150 mm²/sec at 40°C	15 ÷ 150 mm²/sec at 40°C (ISO VG 15 ÷ 100)		
Fluid contamination class	ISO 19/16 achieved with in	ISO 19/16 achieved with in line filters at 25 m and β 25 ≥ 75 (recommended)		
Max working temperature	+99 °C	+99 °C		
Ambient temperature	from -20°C to +70°C	from -20°C to +70°C		
Max pressure	Oil: 12 bar	Water: 12 bar		
Materials	Body: carbon steel	Tubes: copper		

3 PERFORMANCE - with oil temperature 55°C, water temperature 20°C

Model	Recommended oil flow	Cooling power @ ∆T = 35°C	Warning		
X-RE-200	25 ÷ 75 l/min	3 ÷ 6 kW			
X-RE-301	50 ÷ 120 l/min	8 ÷ 13 kW			
X-RE-302	60 ÷ 150 l/min	11 ÷ 18 kW	Oil flow indicated in the table permits to obtain the best performance. Lower oil		
X-RE-502	80 ÷ 200 l/min	17 ÷ 45 kW	flow than minimum reduces the efficency		
			while higher oil flow increases the pressure drop (Δp) whitout efficency improving.		
Y-T60-CB2	5 ÷ 30 l/min	1,3 ÷ 2,5 kW			
Y-T80-CB2	25 ÷ 60 l/min	3 ÷ 4,9 kW			



5 HOW TO CHOOSE THE HEAT EXCHANGER

The total efficency of modern hydraulic plants is about 70 - 80%, so 20 - 30% of installed power become heat and it must be wasted by the heat exchanger.

Generally when we choose a water-oil heat exchanger, it's a good rule to overdimension it by 15 - 20%, because the flow in the circuit is not constant and on the tubes of the water circuit , limestone leaves a deposit reduce the thermical efficency.

Knowing the oil flow, the power to waste and the ΔT (the difference between oil inlet temperature and water inlet temperature), it's possible to determine the best heat exchanger on the diagrams. Proceed as follows:

- knowing the ΔT value, draw a vertical line from the ΔT axis

- knowing the power to waste, draw an horizontal line from the wasted power axis

Intersection point determines the appropriate heat exchanger.


6 MAINTENANCE

OIL SIDE CLEANING: on this side of the circuit, dirt can be removed with a detergent cleaner circulating against the stream: this operation it's takes from 10 to 30 minutes.


During this operation it's recommended to respect anti-pollution norms.

WATER SIDE CLEANING: to guarantee the maximum efficency of the heat exchanger, it's recommended to inspect regularly the water circuit to eliminate limestone or other impurity inside the tubes.

To permit this operation it's necessary to remove two covers and start to clean the tubes with a descaler.



8 DIMENSIONS [mm]



7 DIMENSIONS [mm]